

TOWN OF REDINGTON BEACH
FRIENDSHIP PARK IMPROVEMENTS

INVITATION TO BID

ADDENDUM NO. 2

RESPONSE TO BIDDERS' INQUIRIES
January 10, 2020

Regarding Plan sheet sp1.1, Extend Wall 8'-0" callout, we are unclear on the scope of this callout. What is the intent of extending?

The wall extensions, particularly the northwest one, are a safety measure because of the change of elevation from the deck to the surrounding terrain.

Regarding pergola demo callout, the columns appear to be embedded and/or surface attached to isolated footers. Do you want footers cut off flush or below existing deck level. In either case, how do you want the remaining deck finish left in the four(4) column locations?

Please cut the footers off flush and resurface the deck in the vicinity of the columns to create a safe and smooth surface.

Regarding re-paving path, please confirm type of paving material required. Is the intent to re-surface over the existing stamped and broomed concrete surface?

The pavement is to be poured concrete with a texture that is ADA compliant. The existing pavement is to be removed and replaced.